

 Profibus Master - Modbus RTU Slave

The Anybus X-gateway copies I/O-data in both directions thus enabling data exchange between the two networks. Default I/O configuration is 20 bytes Input and 20 bytes Output. Changing default settings is very simple and is carried out using the RS232 configuration port and a standard terminal interface on a PC, such as Hyper Terminal for Windows.



The Anybus-M Profibus-DP interface supports connection of up to 125 slaves at baudrates up to 12 Mbit/s. The Profibus configuration is defined with NetTool-PB, the windows based configuration software for Profibus from HMS (purchased as a separate accessory). The Profibus interface module is certified by the Profibus user organization and has proven conformance and interoperability with leading manufacturers of I/O, drives, instruments etc Configuration is downloaded to the module via the RS232 configuration port.

The Modbus RTU Slave interface is implemented according to Modbus Protocol ref guide (PI-MBUS-300). All data is mapped to 3x and 4x Modbus areas meaning the Input Status and Output Register Word areas. The Modbus RTU standard baudrate is 19200 Bit/s but can be modified on the gateway between 1200 Bit/s to 57 600 Bit/s.

KEY FEATURES

- Profibus configuration: NetTool-PB for Windows
- Built on Siemens ASIC ASPC2 Step E with Infineon C165

Microprocessor

- Up to 125 slaves can be connected
- Profibus configuration through RS232 configuration port
- Supports PA baud rate 45.45 kbit/s
- Supported Modbus RTU functions: 1, 2, 3, 4, 5, 6, 8, 15, 16, 22, 23
- Modbus RTU transmission media RS485
- Complete Profibus DP Master according to IEC 61158

TECHNICAL SPECIFICATIONS

Size: 126 mm x 110 mm x 42 mm

Power Supply: 24 VDC ($\pm 10\%$)

Temperature: 0-65°C

Current Consump: max 300 mA

I/O Input: Default 20 bytes, max 512 bytes

I/O Output: Default 20 bytes, max 512 bytes

Mech Rating: IP20/Nema1

Config Method: Windows Hyper Terminal

UL certification: E203225, Listed 67AM, UL-1604 Class 1, Div 2, GP A, B, C, D, Temp Code T4

ATEX certification: ATEX 135419, II 3 G, EEx nL IIC T4, DEMKO 03

Power supply connector: 2-pole 5.08 mm Phoenix pluggable screw connector

Profibus baudrate: 9600 bit/s - 12 Mbit/s

Profibus address: Node address 0-125

Profibus connector: D-sub 9-pin female

Accessory order 018330 (NetTool-PB configuration tool for Profibus)

code:

Modbus RTU
baudrate: 1200 Bit/s to 57 600 Bit/s

Modbus RTU
address: Node address 1-247

Modbus RTU
connector: D-sub 9-pin female

Price Group: B

Order Code: AB7808